



TEST RESULTS *POSITION INFORMATION*

REPORTED TO PROJECT Hedley Improvement District
Analytical Testing

WORK ORDER REPORTED 21F3056
2021-06-28 12:12

Analyte	Result	Guideline	RL	Units	Analyzed	Qualifier
---------	--------	-----------	----	-------	----------	-----------

30 hp Well, Pumphouse Tap (21F3056-01) | Matrix: Water | Sampled: 2021-06-22 09:00

Total Metals

Arsenic, total	0.00840	MAC = 0.01	0.00050	mg/L	2021-06-26	
----------------	---------	------------	---------	------	------------	--