

## TEST RESULTS

**REPORTED TO PROJECT** Hedley Improvement District  
Analytical Testing

**WORK ORDER REPORTED** 23A2476  
2023-01-30 13:50

Analyte	Result	Guideline	RL	Units	Analyzed	Qualifier
---------	--------	-----------	----	-------	----------	-----------

30HP Well (23A2476-01) | Matrix: Water | Sampled: 2023-01-24 09:20

**Total Metals**

Arsenic, total	0.00790	MAC = 0.01	0.00050	mg/L	2023-01-30	
----------------	---------	------------	---------	------	------------	--