

# **CERTIFICATE OF ANALYSIS**

**REPORTED TO** Hedley Improvement District

Box 186

Hedley, BC V0X 1K0

**ATTENTION** Hedley Improvement District **WORK ORDER** 23H3899

**PO NUMBER** 

2023-08-30 10:47 / 11.3°C **RECEIVED / TEMP REPORTED** 2023-09-05 18:00 **PROJECT Analytical Testing** 

No Number **PROJECT INFO COC NUMBER** 

#### Introduction:

CARO Analytical Services is a testing laboratory full of smart, engaged scientists driven to make the world a safer and healthier place. Through our clients' projects we become an essential element for a better world. We employ methods conducted in accordance with recognized professional standards using accepted testing methodologies and quality control efforts. CARO is accredited by the Canadian Association for Laboratories Accreditation (CALA) to ISO/IEC 17025:2017 for specific tests listed in the scope of accreditation approved by CALA.

Big Picture Sidekicks

We've Got Chemistry

It's simple. We figure the more you working enjoy with fun and our engaged team the more members; likely you are to give us continued opportunities to support you.

Ahead of the Curve

research, Through regulation and instrumentation, analytical centre the knowledge you

You know that the sample you collected after snowshoeing to site, digging 5 meters, and racing to get it on a plane so you can submit it to the lab for time sensitive results needed to make important and expensive decisions (whew) is VERY important. We know that too.

knowledge, are your technical BEFORE you need it, so you can stay up to date and in the know.

By engaging our services, you are agreeing to CARO Analytical Service's Standard Terms and Conditions outlined here: https://www.caro.ca/terms-conditions

If you have any questions or concerns, please contact me at TeamCaro@caro.ca

### Authorized By:

Team CARO

Client Service Representative



# **TEST RESULTS**

REPORTED TO Hedley Improvement District WORK ORDER

PROJECT Analytical Testing REPORTED 2023-09-05 18:00

Analyte Result Guideline RL Units Analyzed Qualifier

30 HP Pump (23H3899-01) | Matrix: Water | Sampled: 2023-08-29 08:00

Total Metals

Arsenic, total **0.00910** MAC = 0.01 0.00050 mg/L 2023-09-05

23H3899



## **APPENDIX 1: SUPPORTING INFORMATION**

REPORTED TO Hedley Improvement District

**Analytical Testing** 

WORK ORDER REPORTED 23H3899

**PORTED** 2023-09-05 18:00

Analysis Description	Method Ref.	Technique	Accredited	Location
Total Metals in Water	EPA 200.2 / EPA 6020B	HNO3+HCl Hot Block Digestion / Inductively Coupled Plasma-Mass Spectroscopy (ICP-MS)	✓	Richmond

### **Glossary of Terms:**

**PROJECT** 

RL Reporting Limit (default)

MAC Maximum Acceptable Concentration (health based)

mg/L Milligrams per litre

EPA United States Environmental Protection Agency Test Methods

### **Guidelines Referenced in this Report:**

Guidelines for Canadian Drinking Water Quality (Health Canada, September 2022)

Note: In some cases, the values displayed on the report represent the lowest guideline and are to be verified by the end user

#### **General Comments:**

The results in this report apply to the received samples analyzed in accordance with the Chain of Custody document. This analytical report must be reproduced in its entirety. CARO is not responsible for any loss or damage resulting directly or indirectly from error or omission in the conduct of testing. Liability is limited to the cost of analysis. Caro will dispose of all samples within 30 days of sample receipt, unless otherwise agreed. The quality control (QC) data is available upon request

Results in **Bold** indicate values that are above CARO's method reporting limits. Any results that are above regulatory limits are highlighted red. Please note that results will only be highlighted red if the regulatory limits are included on the CARO report. Any Bold and/or highlighted results do <u>not</u> take into account method uncertainty. If you would like method uncertainty or regulatory limits to be included on your report, please contact your Account Manager: TeamCaro@caro.ca

Please note any regulatory guidelines applied to this report are added as a convenience to the client, at their request, to help provide some initial context to analytical results obtained. Although CARO makes every effort to ensure accuracy of the associated regulatory guideline(s) applied, the guidelines applied cannot be assumed to be correct due to a variety of factors and as such CARO Analytical Services assumes no liability or responsibility for the use of those guidelines to make any decisions. The original source of the regulation should be verified and a review of the guideline(s) should be validated as correct in order to make any decisions arising from the comparison of the analytical data obtained to the relevant regulatory guideline for one's particular circumstances. Further, CARO Analytical Services assumes no liability or responsibility for any loss attributed from the use of these guidelines in any way.