



Aug 10/
2022

TEST RESULTS

REPORTED TO PROJECT Hedley Improvement District
Analytical Testing

WORK ORDER REPORTED 22H1008
2022-08-10 17:07

Analyte	Result	Guideline	RL	Units	Analyzed	Qualifier
30HP Well (22H1008-01) Matrix: Water Sampled: 2022-08-08 07:00						
<i>Total Metals</i>						
Arsenic, total	0.00808	MAC = 0.01	0.00050	mg/L	2022-08-10	