



Aug
4/2022

TEST RESULTS

REPORTED TO PROJECT Hedley Improvement District
Analytical Testing

WORK ORDER REPORTED 22G2711
2022-08-04 11:04

Analyte	Result	Guideline	RL	Units	Analyzed	Qualifier
---------	--------	-----------	----	-------	----------	-----------

30HP Well (22G2711-01) | Matrix: Water | Sampled: 2022-07-20

Total Metals

Arsenic, total	0.00786	MAC = 0.01	0.00050	mg/L	2022-08-04	
----------------	---------	------------	---------	------	------------	--